



## PRODUCT SPECIFICATION

**MILLER LEAMAN INC**

800 Orange Ave. Daytona Beach FL 32114

DRAWN	L. Brannan	5/15/20
CHECKED		
ENG APPR.		
MKT APPR.		
SHEET 1 of 1	Ref: ML22481-24T-3P	Rev: B

### SYSTEM REQUIREMENTS:

Electrical: 460VAC/3Ph/60Hz/xxA  
Pressure@Backwash: 30 PSI Max.  
System Pressure: 125 PSI Max.  
Dry Wt: 394 lbs / Operating Wt: 1022 lbs (w/Media)  
Media Req: 350 lbs Est.

TITLE:

**TowerGuard**  
**TG-SS-24T-P62-3P**  
**Media Filter Skid System**  
**(Using Tower Water for Backflush)**