



PRODUCT SPECIFICATION

MILLER LEAMAN INC

800 Orange Ave. Daytona Beach FL 32114

DRAWN	L. Brannan	8/15/18
CHECKED		
ENG APPR.		
MKT APPR.		
SHEET 1 of 1	Ref: ML22481-30T-3P	Rev: A

SYSTEM REQUIREMENTS:

Electrical: 460VAC/3Ph/60Hz/xxA
 System Pressure: 125 PSI Max.
 Pressure@Backwash: 30 PSI Max.
 Dry Wt: 507 lbs / Operating Wt: 1621 lbs (w/Media)
 Media Req: 600 lbs Est.

TITLE:

TowerGuard
TG-SS-30T-P98-3P-SS
Media Filter Skid System
(Using Tower Water for Backflush)