



## PRODUCT SPECIFICATION

**MILLER LEAMAN INC.**

800 Orange Ave. Daytona Beach FL 32114

DRAWN	L. Brannan	4/24/20
CHECKED		
ENG APPR.		
MKT APPR.		
SHEET 1 of 1 Ref: ML22706-36T-3P Rev: B		

### SYSTEM REQUIREMENTS:

Electrical: 460VAC/3Ph/60Hz/xxA  
 System Pressure: 125 PSI Max.  
 Pressure@Backwash: 30 PSI Max.  
 Dry Wt: 635 lbs / Operating Wt: 2480lbs (w/Media)  
 Media Req: 900 lbs Est.

TITLE:

**TowerGuard**  
**TG-SS-36T-P140-3P**  
**Media Filter Skid System**  
**(Using Tower Water for Backflush)**

**PRELIMINARY**