



## PRODUCT SPECIFICATION

**MILLER LEAMAN INC**

800 Orange Ave. Daytona Beach FL 32114

DRAWN	L. Brannan	5/6/20
CHECKED		
ENG APPR.		
MKT APPR.		
SHEET 1 of 1	Ref: ML22706-48T-3P	Rev: A

### SYSTEM REQUIREMENTS:

Electrical: 460VAC/3Ph/60Hz/10A  
 Water Supply Pressure@Inlet: xx PSI Max.  
 Pressure@Backwash: 30 PSI Max.  
 System Pressure: 100 PSI Max.  
 Dry Wt: 1067lbs / Operating Wt: 3962lbs (w/Media)  
 Media Req: 1800lbs Est.

TITLE:

**TowerGuard**  
**TG-SS-48T-P250-3P**  
**Media Filter Skid System**  
**(Using Tower Water for Backflush)**

**PRELIMINARY**