



**PRODUCT SPECIFICATION**

**MILLER LEAMAN INC**

800 Orange Ave. Daytona Beach FL 32114

DRAWN	L. Brannan	6/1/18
CHECKED		
ENG APPR.		
MKT APPR.		
SHEET 1 of 1 Ref: ML22456-42T-3P		Rev: A

**SYSTEM REQUIREMENTS:**  
 Electrical: 460VAC/3Ph/60Hz/xxA  
 System Pressure: 50 PSI Max.  
 Dry Wt: 643 lbs./ Operating Wt: 2964 lbs. (w/Media)  
 Media Req: 1300 lbs. Est.

TITLE: **TowerGuard**  
**TG-FG-42T-P190-3P**  
 Media Filter Skid System  
 (Using Tower Water for Backwash)