



PRODUCT SPECIFICATION

MILLER LEAMAN INC

800 Orange Ave. Daytona Beach FL 32114

DRAWN	L. Brannan	6/1/18
CHECKED		
ENG APPR.		
MKT APPR.		
SHEET 1 of 1 Ref: ML22456-48T-3P		Rev: A

SYSTEM REQUIREMENTS:
 Electrical: 460VAC/3Ph/60Hz/xxA
 System Pressure: 50 PSI Max.
 Dry Wt: 844 lbs./ Operating Wt: 4208 lbs. (w/Media)
 Media Req: 1800 lbs. Est.

TITLE: **TowerGuard**
TG-FG-48T-P250-3P
 Media Filter Skid System
 (Using Tower Water for Backwash)